

# STEDRANT TECHNOCLINIC PVT. LTD.

#### (Construction Materials Testing Laboratory)

Lab: # 39/5, Govardhan Garden, J C Industrial Area, Yelechenahalli, off. Kanakapura Main Road, Bangalore - 560062. Ph.: 080 26860348. E-mail : labblr@stedrant.com CIN: U74999KA2017PTC100477

GST No.: **29AAYCS1231L1ZQ** www.stedrant.com



TC-6899

DOC: STPL/MTD/Paver/RF-29

Ref: STPL/PB/JO/293/12/2021-22/2/AS

Test Order dated: 18.12.2021

M/s. Sinter Machines

35, Peelamedu Industrial Estate

V K Road, Peelamedu, Coimbatore 641 004,

India.

Page 1 of 1

Date: 24.12.2021

ULR-TC689921000011397F



### TEST REPORT ON PAVER BLOCKS

Source of sample

: Sample supplied by customer

Date of receipt of the test sample

15.12.2021

Customer's Reference

Email Dated 16.12.2021

No. of samples tested

3 (three)

Project#

Not furnished

Period of test

20.12.2021 to 21.12.2021

Condition of samples

Satisfactory

Technical Reference

IS: 15658 – 2021

Sl. No.	Sample ID#	Thickness (mm)	Compressive Strength (N/Sq. mm)
1	1	60	38.1
2	2	60	31.2
3	3	60	37.4

## # As furnished by the customer

Note:

- 1. The results relate only to the items tested.
- 2. Report shall not be reproduced, except in full, without the written approval of the lab.
- 3. Any correction invalidates this report.

#### for STEDRANT TECHNOCLINIC PRIVATE LIMITED

End of the report

Radhakrishna STPL Manager-Lab

(Soil and Material Testing, Designs, Restoration and Non Destructive Testing Services)